

ELMIRA WATER BOARD
Elmira, New York
Bids for Estimated 2022 Requirements for:

SPECIFICATIONS
TYTON JOINT DUCTILE IRON PIPE

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 1:30 P.M., EST, on Tuesday, October 19, 2021. At this time the bids will be publicly opened and read.

The pipe joint fittings shall be push-on joints and the pipe shall be centrifugally cast ductile iron pipe conforming with ANSI A 21.51-1986 Class 52 pipe complete with accessories. Pipe shall be double cement lined with paint seal coat and tar coated on the outside in accordance with ANSI specifications A 21.4-1990. **Tyton push-on joint rubber gaskets and joint lubricant shall conform with ANSI specifications A 21.11-1990.**

Bids shall be quoted on the below quotation form. Bid price should include freight delivered to the Elmira Water Board's Maintenance Shop yard at 760 Bonview Street, Elmira, New York.

Bids must be in sealed envelopes, ATTN: Denise Mullaney, and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Elmira Water Board reserves the right to waive any informalities and to reject any or all bids and to re-advertise for new bids at its discretion.

BIDDER NAME: _____

Phone: _____ Fax: _____

Email: _____

QUOTATION FORM

<u># OF UNITS</u>	<u>SIZE</u>	<u>COST/UNIT</u>	<u>EXTENDED TOTAL</u>
500'	4"	_____	_____
4,000'	6"	_____	_____
2,000'	8"	_____	_____
1,000'	10"	_____	_____
200'	12"	_____	_____
60'	16"	_____	_____
200'	20"	_____	_____

QUOTATION FORM cont'd

<u># OF UNITS</u>	<u>SIZE</u>	<u>COST/UNIT</u>	<u>EXTENDED TOTAL</u>
80'	24"	_____	_____
80'	30"	_____	_____
TOTAL PRICE DOLLARS			\$_____