



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0K0258

Client Sample ID:	Foster Island 840	Collected By:	Rose Marino
Sample Matrix:	Drinking Water	Collection Date:	11/17/2020 14:00
Lab Sample ID:	S0K0258-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Volatile Organic Compounds by GCMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 524.2, Rv. 4.1 (1995)								
Benzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Bromobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Bromochloromethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Bromodichloromethane	<0.50		0.50	ug/L			11/23/20 1740	RSD
Bromoform	<0.50		0.50	ug/L			11/23/20 1740	RSD
Bromomethane	<0.50		0.50	ug/L			11/23/20 1740	RSD
tert-Butylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
sec-Butylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
n-Butylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Carbon tetrachloride	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Chlorobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Chloroethane (Ethyl chloride)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Chloroform	<0.50		0.50	ug/L			11/23/20 1740	RSD
Chloromethane	<0.50		0.50	ug/L			11/23/20 1740	RSD
2-Chlorotoluene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
4-Chlorotoluene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Dibromochloromethane	<0.50		0.50	ug/L			11/23/20 1740	RSD
Dibromomethane (Methylene bromide)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,4-Dichlorobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2-Dichlorobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,3-Dichlorobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Dichlorodifluoromethane (Freon-12)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2-Dichloroethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,1-Dichloroethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
trans-1,2-Dichloroethene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
cis-1,2-Dichloroethene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,1-Dichloroethene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,3-Dichloropropane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
2,2-Dichloropropane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2-Dichloropropane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,1-Dichloropropene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
trans-1,3-Dichloropropene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
cis-1,3-Dichloropropene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Ethylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Hexachlorobutadiene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Isopropylbenzene (Cumene)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
4-Isopropyltoluene (p-Isopropyltoluene)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Methyl tert-butyl ether (MTBE)	<0.50	10 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Methylene chloride (Dichloromethane)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Naphthalene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
n-Propylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Styrene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD

Microbac Laboratories, Inc.



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0K0258

Client Sample ID: <u>Foston (plant #40)</u>	Collected By: <u>Rose Marino</u>
Sample Matrix: <u>Drinking Water</u>	Collection Date: <u>11/17/2020 14:00</u>
Lab Sample ID: <u>S0K0258-02</u>	

Volatile Organic Compounds by GCMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
1,1,1,2-Tetrachloroethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,1,2,2-Tetrachloroethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Tetrachloroethene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Toluene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2,4-Trichlorobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2,3-Trichlorobenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,1,1-Trichloroethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,1,2-Trichloroethane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Trichloroethene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Trichlorofluoromethane (Freon 11)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2,3-Trichloropropane	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,2,4-Trimethylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
1,3,5-Trimethylbenzene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Vinyl chloride	<0.50	2 NYVOA	0.50	ug/L			11/23/20 1740	RSD
m,p-Xylene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
o-Xylene	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Xylenes (total)	<0.50	5 NYVOA	0.50	ug/L			11/23/20 1740	RSD
Surrogate: 4-Bromofluorobenzene	86.2	Limit: 70-130		% Rec			11/23/20 1740	RSD
Surrogate: 1,2-Dichlorobenzene-d4	92.4	Limit: 70-130		% Rec			11/23/20 1740	RSD