

ELMIRA WATER BOARD

Elmira, New York

Bids for Estimated 2020 Requirements for:

SPECIFICATIONS

COPPER COMPRESSION COUPLINGS, COPPER COMPRESSION CORPORATION STOPS

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 1:30 P.M., EST, on Wednesday, October 23, 2019. At this time the bids will be publicly opened and read.

The copper coils shall be 3/4" diameter, type K soft copper in coils of 60' and shall be in conformance with ANSI/NSF-61-25XN and ASTM B-88.

The copper compression couplings shall be 3/4" in diameter, McDonald #74758Q, Mueller H-15403N or Ford #C44-33-Q-NL ONLY.

The copper compression corporation stops shall be 3/4" in diameter, McDonald #74704BQ, Mueller B-25008N, or Ford #F1100-3-MR-Q-NL ONLY.

The copper compression curb stops shall be 3/4" McDonald #76100Q, Mueller #B25209N, Ford #B44-333-Q-NL ball valve, ball valve type with quick joint ends ONLY.

Male Iron Pipe (MIP) by Compression shall be 3/4" McDonald #74753Q, Mueller part #H15428N or Ford #C84-33-Q-NL

Female Iron Pipe (FIP) by Compression shall be 3/4" McDonald #74754Q, Mueller #H-15451N or Ford #C14-33-Q-NL

All the above pipe and fittings will be ordered as one shipment not to exceed 60 days from award confirmation date, and are to be delivered to the Elmira Water Board Maintenance Shop at 760 Bonview Street, Elmira, New York.

Bids shall be quoted on the below quotation form. Bid price should include freight delivered to the Elmira Water Board's Maintenance Shop yard at 760 Bonview Street, Elmira, New York.

Bids must be in sealed envelopes, ATTN: Denise Mullaney, and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Elmira Water Board reserves the right to waive any informalities and to reject any or all bids and to re-advertise for new bids at its discretion.

BID SHEET

**Copper Compression Couplings,
Copper Compression Corporation Stops**

BIDDER NAME: _____

Phone: _____ Fax: _____

Email: _____

QUOTATION FORM

<u># Of Units</u>	<u>Size</u>	<u>Cost/Unit</u>	<u>Extended Total</u>
3,000' Type "K" copper 60ft coils	3/4"	_____	_____
120 couplings (each)	3/4"	_____	_____
120 corporation stops (each)	3/4"	_____	_____
120 compression curb stop (each)	3/4"	_____	_____
**MIP by compression (each)	3/4"	_____	_____
**FIP by compression (each)	3/4"	_____	_____
** quantity as needed			

TOTAL PRICE DOLLARS _____