

ELMIRA WATER BOARD

Elmira, New York

Bids for Estimated 2026 Requirements for:

PRICING IS FOR JANUARY 1, 2026 through DECEMBER 31, 2026

SPECIFICATIONS KENNEDY VALVE GUARDIAN HYDRANTS

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 1:30 P.M., EST, on Wednesday, October 15, 2025. At this time the bids will be publicly opened and read.

Hydrants are to conform to Kennedy Valve Guardian hydrant specifications, open left, with 5¼" main valve openings, 1 1/8" pentagon operating and cap nuts, 2 hose nozzles with 2½" national standard thread, 1 steamer nozzle with 4½" national standard thread.

Hydrants shall be yellow in color with 6" mechanical joint elbows.

The price quoted is to include delivery to the Elmira Water Board Maintenance Shop at 760 Bonview Street, Elmira, New York.

Bids shall be quoted on the below quotation form.

Bids must be in sealed envelopes, ATTN: Denise Mullaney, and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Iranian Energy Divestment Certificate, Bidder's Statement on Sexual Harassment, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Elmira Water Board reserves the right to waive any informalities and to reject any or all bids and to re-advertise for new bids at its discretion.

BIDDER NAME: _____

Phone: _____ Fax: _____

EMAIL: _____

QUOTATION FORM

<u># OF UNITS</u>	<u>LENGTH</u>	<u>COST/UNIT</u>	<u>EXTENDED TOTAL</u>
25	5'0"	_____	_____
25	5'6"	_____	_____
20	6'0"	_____	_____
2	6'6"	_____	_____
2	7'0"	_____	_____

TOTAL PRICE DOLLARS

\$ _____