



RAdata, LLC
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: Robert Sanders
 Search Day Program
 73 Wickapecko Drive
 Ocean, NJ 077120000

Laboratory Results

Sample Number	Sample Location	Collected By
0422-9720	73 Wickapecko Drive - Ocean Twp	customer

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0422-9720	4/14/2022 6:00:00 AM Boys Lavatory Sink 1	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-10	4/14/2022 6:15:00 AM Girls Lavatory Sink 4	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-11	4/14/2022 6:15:00 AM Girls Lavatory Sink 5	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-12	4/14/2022 6:15:00 AM Girls Lavatory Sink 6	4/21/2022 8:26:00 AM	Lead (1st Draw)	7.51 ug/l	15 ug/L	Std Method 3113B
0422-9720-13	4/14/2022 6:30:00 AM Classroom 111 Bathroom Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-14	4/14/2022 6:35:00 AM Classroom 115 Bathroom Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-15	4/14/2022 6:40:00 AM Nurses Lavatory Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-16	4/14/2022 6:40:00 AM Nurses Office Sink Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-17	4/14/2022 6:45:00 AM Conference Room Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-18	4/14/2022 6:50:00 AM Staff Bathroom Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-19	4/14/2022 7:00:00 AM Practice Room Faucet	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-2	4/14/2022 6:00:00 AM Boys Lavatory Sink 2	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-3	4/14/2022 6:00:00 AM Boys Lavatory Sink 3	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-4	4/14/2022 6:00:00 AM Boys Lavatory Sink 4	4/21/2022 8:26:00 AM	Lead (1st Draw)	2.57 ug/l	15 ug/L	Std Method 3113B
0422-9720-5	4/14/2022 6:00:00 AM Boys Lavatory Sink 5	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, April 25, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 2



RAdata, LLC
 27 Ironia Road, Unit 2
 Flanders, NJ 07836
 973-927-7303 Phone
 973-927-4980 Fax

Customer: Robert Sanders
 Search Day Program
 73 Wickapecko Drive
 Ocean, NJ 077120000

Laboratory Results

Sample Number	Sample Location	Collected By
0422-9720	73 Wickapecko Drive - Ocean Twp	customer

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0422-9720-6	4/14/2022 6:00:00 AM Boys Lavatory Sink 6	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-7	4/14/2022 6:15:00 AM Girls Lavatory Sink 1	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-8	4/14/2022 6:15:00 AM Girls Lavatory Sink 2	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
0422-9720-9	4/14/2022 6:15:00 AM Girls Lavatory Sink 3	4/21/2022 8:26:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

**The parameters tested on this report PASSED NJ
 Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.