



SULLIVAN FIRE PROTECTION DISTRICT

Office of the Fire Marshal: Corey Rice
P.O. Box 475 • SULLIVAN, Mo. 63080 • 573-468-6161 • FAX 573-468-2623

Ordinance 21-01

SULLIVAN FIRE PROTECTION DISTRICT ORDINANCE

WHEREAS, within the territory included within the Sullivan Fire Protection District, the inhabitants and the structures require protection from fire hazards and assistance for the prevention of fires, so that a code is necessary to enable such protection and prevention, and the Fire Protection District is specifically given power to adopt such a code pursuant to Chapter 321 of the Revised Statutes of Missouri, and the Board of Directors of the Sullivan Fire Protection District finds that such matters may properly be provided by Ordinance;

NOW, THEREFORE, be it ordained by the Board of Directors of the Sullivan Fire Protection District as follows:

ORDINANCE No. 21-01

An Ordinance for Adoption of the 2018 International Fire Code

An ordinance of the Sullivan Fire Protection District, comprising portions of Franklin, Crawford and Washington Counties, Missouri, adopting the *2018 International Fire Code*, regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the Sullivan Fire Protection District; providing for the issuance of permits for hazardous uses or operations.

SECTION 1. ADOPTION OF THE FIRE CODE: That certain documents, copies of which are on file in the office of the Fire Code Official of the Sullivan Fire Protection District and can be viewed at, <https://sullivanfpd.com/fire-prevention>, being marked and designated as the “**International Fire Code**”, including Appendix Chapters B through G and excluding Appendix Chapter A, as published by the International Code Council, Inc. referenced herein are hereby adopted and declared to be **The Fire Code of the Sullivan Fire Protection District, Missouri**, for the control of buildings and structures and each and all of the regulations, provisions, penalties, conditions, and terms of the “International Fire Code” 2018 Edition, as published by the International Code Council, Inc. referenced herein are hereby referred to, adopted and made part hereto by reference, as is fully set out in this Ordinance, with the additions, insertion, deletions, and changes, if any, prescribed in the following sections of this Ordinance. This ordinance is effective for all portions of the Sullivan Fire Protection District including those portions of Crawford, Washington and Franklin counties of Missouri including the city of Sullivan.

- A. Ordinance No.20-01, of the Sullivan Fire District is hereby repealed; all other previous fire prevention codes in conflict with this ordinance are also repealed.

Section 2. The following shall be added to, inserted in, deleted from, or changed in the "INTERNATIONAL FIRE CODE. FIRST PRINTING, 2018 EDITION, INCLUDING APENDIX CHAPTERS B, D, E, F, I, AND K" in this ordinance.

Section 105.1.2 is hereby amended and shall read as follows: **Types of permits.**

Section 105.1.2 Types of permits. There shall be three types of permits as follows:

1. Occupancy permit. An operational permit allows the applicant to conduct an operation or a business for which a permit is required by section 105.6 for either:
 - 1.1 Change in occupancy
 - 1.2 Change in ownership
 - 1.3 Change in business name
 - 1.4 Change in location
2. Building construction permit. A Fire Building permit shall be required in new construction or alterations or modifications of systems and equipment which a permit is required by section 105.7
3. Firework permit. A fire work permit shall be required before stocking or operating any firework stand. A fire work permit shall be required for any static displays within the Sullivan Fire District. Permits will be valid from twentieth (20th) day June through tenth (10th) day of July. Any other sale outside this time frame will be at the discretion of the Fire Code Official.

Section 114 is hereby added and shall read as follows: **Schedule of permit fees:**

Section 114.1 Schedule of permit fees:

1. Fire District Building permit will be based on square feet. Rate is set to .08/sq. ft.
2. Minimum permit fee \$150
3. Starting construction without a permit \$200
4. Sprinkler System \$150
5. Institutional \$150
6. Educational \$150
7. Assembly \$100
8. High Hazard \$300
9. Occupancy \$25
10. Firework \$75
11. Additional Inspections \$50
12. Storage Sheds \$200

Section 504.1.1 is hereby added and shall read as follows: Door Numbering System

504.1.1 Door Numbering System for Large/Special Occupancies. In large occupancies and occupancies deemed as special classifications; the needs of a door numbering system shall be required. Occupancies shall number all entry and exit doors from the exterior and interior to identify that door in the event of an emergency. The door number would be used during emergencies for responders to use for a direct access closest to the emergent situation. The numbering of doors will be in sequence increasing clockwise around the building with the first door being the main entrance. The numbers on the exterior must coincide with the numbers on the interior so that they are the same number. All numbers must be at least six (6") in height and one (1") in width. The numbers must be colored as to be visible and must be in contrast with the color of the door. A door numbering system is mandatory for all educational occupancies.

Section 505.1 is hereby amended and shall read as follows: Address Identification

Section 505.1 New and existing buildings shall be provided with the approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification shall contrast to with their background. Address numbers shall be Arabic or Alphabetical letters. Numbers shall not be spelled out. Each character shall not be less than 6 inches high with a minimum stroke width of 1 inch. Where required by the *Fire Code Official*, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole, or other sign shall be used to identify the structure. Address identification shall be maintained.

Section 506.1.3 is hereby added and shall read as follows: Key Boxes

Section 506.1.3 Knox boxes. Shall be required on all new commercial construction within the Sullivan Fire District. Any remodels, new occupancies, or new additions, such as but not limited to, gates, fences, and cables, shall be required to install a Knox Box according to section 506.1.5

Section 506.1.4 is hereby added and shall read as follows: Gates and Fences

Section 506.1.4 Businesses within the Sullivan Fire District that has a gate or fence that restricts emergency access shall have a Knox Box located outside the gate. Knox box shall be installed according to section 506.1.5.

Section 506.1.5 is hereby added and shall read as follows: Knox Box Mounting Location

Section 506.1.5 Knox Boxes for Fire District access shall be mounted within 3ft. to the right of the front door, not less than 3 ft. from the ground, and no more than 5 ft. from the ground. Any gate or fence shall have a key box mounted outside the gate on the

right side not less than 3 ft. from the ground, and no more than 5 ft. from the ground. When a building or gate does not allow mounting per code, it will be up to the *fire code official* on mounting location.

Section 903.2 is hereby amended and shall read as follows: Where required

Section 903.2 Where required. Fire suppression systems shall be installed and maintained in full operating condition, as specified in this code:

1. When more than three (3) stories or fifty (50) feet in height.
2. In locations indicated in section 903.2.1 through 903.2.12

Section 903.4.2.1 is hereby added and shall read as follows: Locating FDC

Section: 903.4.2.1 Strobe Light Visible Locating FDC. All buildings that have a fire department connection that is attached to the building must have installed a flashing strobe light that is in accordance with NFPA 72 onto the exterior of the building directly above the fire department connection or as directed by the *fire code official*.

Section 912.5 is hereby amended and shall read as follows: Signs

Section: 912.5 Signs. The fire department connection shall be identified with a metal sign that reads "FDC" in red reflective lettering on a white background. The Sign shall be a minimum of 12" x 12". Letters shall be minimum of 6 inches in height and 3 inches in width.

Section 3. That nothing in this ordinance or in the *Fire Code* hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 3 of this ordinance; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this ordinance.

Section 4. If any Section, subsection, provision, sentence, clause or phrase of this Ordinance or of the *2018 International Fire Code* is for any reason held to be unconstitutional or invalid, such decision shall not affect the validity of the remaining portions of this Ordinance or of said Code, and the Sullivan Fire Protection District hereby declares that it would have passed the same, even though such portions so held to be unconstitutional had not been included therein.

Section 5. In the event that the Sullivan Fire Protection District initiates any legal action in order to compel compliance with and/or prevent violation(s) of any of the provisions enumerated herein, the District shall be entitled to recover from the offending party or parties any and all attorneys' fees and costs associated with the bringing of such an action.

Section 6. That this Ordinance Number 20-01, having been duly considered and voted upon by the Board of Directors of the Sullivan Fire Protection District was enacted as an Ordinance of said Fire

Protection District on the 9th Day of November, 2020. The Secretary of the Sullivan Fire Protection District shall cause the same to be published as required by law; and this ordinance shall take effect and be in force at 12:01 a.m. on the 1st day of January, 2021



Frank S. Blanton
President & Director



Jordan Tod
Vice President & Director



Chris Garner
Treasurer & Director



