

(5 to 45 Amp MCB BS 3871)

**1997 16th Edition (1992 +Amd 2 1997) C & G 2391 - EFLL MCB + RCBO (0.4 or 5 seconds disconnection time) (Zs)**

$U_0$  is the nominal a.c. rms line voltage to Earth.  
 $I_a$  is the current causing operation of the protective device within the specified time.  
 $Z_s = \frac{U_0}{I_a}$

The results given below have been obtained from circuits in a domestic installation.  
 NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**Disconnection time for circuits in TN system = 0.4s / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.8? The Max Zs values in the "BS7671" are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the "On-site guide" are all 0.8 (80%) of the values in the "Regs Book" - this to my understanding is the 0.8 "Rule of Thumb" figure allowing suitable correction for temperature, generally used when testing your new installed work.  
 However, the BS7671 16th EDITION (No.1 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) "rule of thumb figures"  
 GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG, aimed at new work you are designing & installing (known cables) (NSI, aimed at other persons work such as PIR (EICR) type, unknown cables sizes).  
 32A type B 60898  
 16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
 15A 3036 0.4sec  
 16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

**1997 16th Edition (1992 +Amd 2 1997) C & G 2391 - EFLL MCB + RCBO (0.4 or 5 seconds disconnection time) (Zs)**

$U_0$  is the nominal a.c. rms line voltage to Earth.  
 $I_a$  is the current causing operation of the protective device within the specified time.  
 $Z_s = \frac{U_0}{I_a}$

The results given below have been obtained from circuits in a domestic installation.  
 NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**Disconnection time for circuits in TN system = 0.4s / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.8? The Max Zs values in the "BS7671" are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the "On-site guide" are all 0.8 (80%) of the values in the "Regs Book" - this to my understanding is the 0.8 "Rule of Thumb" figure allowing suitable correction for temperature, generally used when testing your new installed work.  
 However, the BS7671 16th EDITION (No.1 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) "rule of thumb figures"  
 GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG, aimed at new work you are designing & installing (known cables) (NSI, aimed at other persons work such as PIR (EICR) type, unknown cables sizes).  
 32A type B 60898  
 16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
 15A 3036 0.4sec  
 16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

**BS7671 16th EDITION (No.1 2002 + No. 2 2004) (BROWN BOOK) C & G 2391 - EFLL (Zs) MCB + RCBO (0.4 or 5 seconds disconnection time)  $U_{oc} = 240 V$**

$U_{oc}$  is the open circuit voltage at the distribution transformer.  
 $I_a$  is the current causing operation of the protective device within the specified time.  
 $Z_s = \frac{U_{oc}}{I_a}$

The results given below have been obtained from circuits in a domestic installation.  
 NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**Disconnection time for circuits in TN system = 0.4s / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.8? The Max Zs values in the "BS7671" are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the "On-site guide" are all 0.8 (80%) of the values in the "Regs Book" - this to my understanding is the 0.8 "Rule of Thumb" figure allowing suitable correction for temperature, generally used when testing your new installed work.  
 However, the BS7671 16th EDITION (No.1 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) "rule of thumb figures"  
 GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG, aimed at new work you are designing & installing (known cables) (NSI, aimed at other persons work such as PIR (EICR) type, unknown cables sizes).  
 32A type B 60898  
 16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
 15A 3036 0.4sec  
 16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

**BS7671 16th EDITION (No.1 2002 + No. 2 2004) (BROWN BOOK) C & G 2391 - EFLL (Zs) MCB + RCBO (0.4 or 5 seconds disconnection time)  $U_{oc} = 240 V$**

$U_{oc}$  is the open circuit voltage at the distribution transformer.  
 $I_a$  is the current causing operation of the protective device within the specified time.  
 $Z_s = \frac{U_{oc}}{I_a}$

The results given below have been obtained from circuits in a domestic installation.  
 NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**Disconnection time for circuits in TN system = 0.4s / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.8? The Max Zs values in the "BS7671" are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the "On-site guide" are all 0.8 (80%) of the values in the "Regs Book" - this to my understanding is the 0.8 "Rule of Thumb" figure allowing suitable correction for temperature, generally used when testing your new installed work.  
 However, the BS7671 16th EDITION (No.1 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) "rule of thumb figures"  
 GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG, aimed at new work you are designing & installing (known cables) (NSI, aimed at other persons work such as PIR (EICR) type, unknown cables sizes).  
 32A type B 60898  
 16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
 15A 3036 0.4sec  
 16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

(5 to 45 Amp MCB BS 3871)

### 2008 BS7671 17th EDITION (RED BOOK) C & G 2391 - EFLI

#### MCB + RCBO (0.4 or 5 seconds disconnection time) (Zs)

$U_0$  is the nominal a.c. rms line voltage to Earth.  $Z_s = \frac{U_0}{I_a}$

$Z_e = \dots \Omega$   $I_a$  is the current causing operation of the protective device within the specified time.

The results given below have been obtained from circuits in a domestic installation.

NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**U<sub>0</sub> 230V**

**AC**

**0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this is my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 2 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'

GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit! So, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) OSG - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.

32A type B 60898  
16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
15A 3036 0.4sec  
16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

### 2008 BS7671 17th EDITION (RED BOOK) C & G 2391 - EFLI

#### MCB + RCBO (0.4 or 5 seconds disconnection time) (Zs)

$U_0$  is the nominal a.c. rms line voltage to Earth.  $Z_s = \frac{U_0}{I_a}$

$Z_e = \dots \Omega$   $I_a$  is the current causing operation of the protective device within the specified time.

The results given below have been obtained from circuits in a domestic installation.

NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**U<sub>0</sub> 230V**

**AC**

**0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this is my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 2 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'

GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit! So, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) OSG - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.

32A type B 60898  
16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
15A 3036 0.4sec  
16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

### BS7671:2008 17th EDITION (Amendment No 1 :2011)

#### EARTH FAULT LOOP IMPEDANCE (Zs)

$U_0$  is the nominal a.c. rms line voltage to Earth.  $Z_s = \frac{U_0}{I_a}$

$Z_e = \dots \Omega$   $I_a$  is the current causing operation of the protective device within the specified time.

The results given below have been obtained from circuits in a domestic installation.

NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**U<sub>0</sub> 230V**

**AC**

**0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this is my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 2 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'

GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit! So, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) OSG - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.

32A type B 60898  
16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
15A 3036 0.4sec  
16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

### BS7671:2008 17th EDITION (Amendment No 1 :2011)

#### EARTH FAULT LOOP IMPEDANCE (Zs)

$U_0$  is the nominal a.c. rms line voltage to Earth.  $Z_s = \frac{U_0}{I_a}$

$Z_e = \dots \Omega$   $I_a$  is the current causing operation of the protective device within the specified time.

The results given below have been obtained from circuits in a domestic installation.

NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

**U<sub>0</sub> 230V**

**AC**

**0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω
		Ω	Ω	Ω	Ω

3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this is my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 2 2002 + No. 2 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'

GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / consumer unit. Older wires with 1.0mm CPC may be present at other parts of the circuit! So, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) OSG - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.

32A type B 60898  
16" = 1.50 OSG=1.20 (80% of 16") 17" = 1.44 (96% of 16")  
15A 3036 0.4sec  
16" = 2.67 OSG= 2.14 (80% of 16") 17" = 2.55 (96% of 16")

(5 to 45 Amp MCB BS 3871)

### BS7671:2008 17th EDITION 2015 (Amendments 1, 2 + 3) EARTH FAULT LOOP IMPEDANCE $Z_s \times I_a \leq U_0 \times C_{min}$

$Z_e = \quad \Omega$

The results given below have been obtained from circuits in a domestic installation.

NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

$C_{min} = 0.95$   $U_0 \leq 230 V$  **AC**

Disconnection time for circuits in TN system = 0.4s / 5s **0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$

*3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this to my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 1, 2002 + No. 2, 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'*

*GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / Consumer Unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) GNS - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.*

*32A type B 60898*  
 $16'' = 1.50 \text{ OSG} = 1.20 \text{ (80\% of } 16'') \text{ } 17'' = 1.44 \text{ (96\% of } 16'')$   
 15A 3036 0.4sec  
 $16'' = 2.67 \text{ OSG} = 2.14 \text{ (80\% of } 16'') \text{ } 17'' = 2.55 \text{ (96\% of } 16'')$

### BS7671:2008 17th EDITION 2015 (Amendments 1, 2 + 3) EARTH FAULT LOOP IMPEDANCE $Z_s \times I_a \leq U_0 \times C_{min}$

$Z_e = \quad \Omega$

The results given below have been obtained from circuits in a domestic installation.

NB: Assumption that the cables are Twin with reduced CPC and establishes whether or not the measured values are acceptable.

$C_{min} = 0.95$   $U_0 \leq 230 V$  **AC**

Disconnection time for circuits in TN system = 0.4s / 5s **0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$

*3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this to my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 1, 2002 + No. 2, 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'*

*GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / Consumer Unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) GNS - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.*

*32A type B 60898*  
 $16'' = 1.50 \text{ OSG} = 1.20 \text{ (80\% of } 16'') \text{ } 17'' = 1.44 \text{ (96\% of } 16'')$   
 15A 3036 0.4sec  
 $16'' = 2.67 \text{ OSG} = 2.14 \text{ (80\% of } 16'') \text{ } 17'' = 2.55 \text{ (96\% of } 16'')$

### THE EARTH FAULT LOOP IMPEDANCE 18th Edition BS7671 (2018)

Earth Fault Loop Impedance analysis for final circuits with a rated current not exceeding: (i) 63 A with one or more socket-outlets, and  $Z_s \times I_a \leq U_0 \times C_{min}$

(ii) 32 A supplying only fixed connected current-using equipment

The results given below have been obtained from circuits in a domestic installation.

$Z_e = \quad \Omega$   $C_{min} = 0.95$   $U_0 \leq 230 V$  **AC**

Disconnection time for all circuits in TN system = 0.4s **0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$

*3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this to my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 1, 2002 + No. 2, 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'*

*GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / Consumer Unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) GNS - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.*

*32A type B 60898*  
 $16'' = 1.50 \text{ OSG} = 1.20 \text{ (80\% of } 16'') \text{ } 17'' = 1.44 \text{ (96\% of } 16'')$   
 15A 3036 0.4sec  
 $16'' = 2.67 \text{ OSG} = 2.14 \text{ (80\% of } 16'') \text{ } 17'' = 2.55 \text{ (96\% of } 16'')$

### THE EARTH FAULT LOOP IMPEDANCE 18th Edition BS7671 (2018)

Earth Fault Loop Impedance analysis for final circuits with a rated current not exceeding: (i) 63 A with one or more socket-outlets, and  $Z_s \times I_a \leq U_0 \times C_{min}$

(ii) 32 A supplying only fixed connected current-using equipment

The results given below have been obtained from circuits in a domestic installation.

$Z_e = \quad \Omega$   $C_{min} = 0.95$   $U_0 \leq 230 V$  **AC**

Disconnection time for all circuits in TN system = 0.4s **0.4 / 5s**

Test	Circuit Description	BS7671 Value	BS7671 Value multiply by 0.8 3/4 Rule of Thumb	Measured Value	Satisfactory Yes / No
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$
		$\Omega$	$\Omega$	$\Omega$	$\Omega$

*3/4 or 0.87 The Max Zs values in the 'BS7671' are prior to any correction factors allowing for things such as ambient temperature of conductors during fault condition. The Zs values in the 'On-site guide' are all 0.8 (80%) of the values in the 'Regs Book' - this to my understanding is the 0.8 'Rule of Thumb' figure allowing suitable correction for temperature, generally used when testing your new installed work. However, the BS7671 16th EDITION (No. 1, 2002 + No. 2, 2004) GNS Inspection & Testing (4th Edition) April 2006 Rule of thumb refers to a 3/4 Zs value - see page 56 of GNS, point 4) 'Rule of thumb figures'*

*GNS also mentions allowances for unknown CPC conductor sizes - which to my understanding is when tested unknown cables (e.g. PIR / EICR) although a ring may have a 2.5 with 1.5mm CPC at the fuse box / Consumer Unit. Older wires with 1.0mm CPC may be present at other parts of the circuit so, a 3/4 or 75% Zs value gives and extra 5% margin of safety compared to the 80% on site guide values! OSG - aimed at new work you are designing & installing (known cables) GNS - more aimed at other persons work such as PIR (EICR) type, unknown cables sizes.*

*32A type B 60898*  
 $16'' = 1.50 \text{ OSG} = 1.20 \text{ (80\% of } 16'') \text{ } 17'' = 1.44 \text{ (96\% of } 16'')$   
 15A 3036 0.4sec  
 $16'' = 2.67 \text{ OSG} = 2.14 \text{ (80\% of } 16'') \text{ } 17'' = 2.55 \text{ (96\% of } 16'')$