

Drinking Water Quality and Compliance Town of Springside – Annual Notice to Consumers

Introduction

The Water Security Agency and the Ministry of Environment require that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Town of Springside's water quality and sample submission compliance record for the January 1 – December 31, 2024 time period. This report was completed on May 23, 2025. Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	1 per week	52	0
E. coli	0 Organisms/100 mL	1 per week	52	0
Background Bacteria	Less than 200/100 mL	1 per week	52	0

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.30-1.93	0.18-1.76	52	52	100%

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.21	.17-2.00	365	4

A minimum of 0.21 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system as required in the permit to operate a waterworks. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.21 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.00	0.20-0.94	0	0.94	365	365

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium. The last sample for Chemical Health analysis was required in 2023 and submitted on February 12, 2023.

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids. The last sample for General Chemical analysis was required in 2023 and submitted on February 23, 2025.

More information on water quality and sample submission performance may be obtained from:
Town of Springside, Box 414, Springside, SK S0A 3V0; phone: 306-792-2022; email: springside@sasktel.net



**Saskatchewan
Ministry of
Environment**

