



47.7 Marking.

All transparent glass doors and fixed adjacent transparent glass sidelights shall be marked as hereinafter required, regardless of the type of glazing material used in their construction. Marking of all transparent glass doors and fixed adjacent transparent glass sidelights within six feet horizontally shall be of an opaque nature placed as hereinafter described in section 47.8 below and shall be of such a design as to be readily discernible to any person approaching the doors and sidelights from any direction.

Historical Note
Sec. added, filed Dec. 21, 1967 to be eff. Jan. 1, 1968.

47.8 Marking locations.

Transparent glass doors and fixed adjacent transparent glass sidelights shall be marked in two areas on the glass surface thereof. One such area shall be located at least 30, but not more than 36 inches and the other at least 60, but not more than 66 inches above the ground, floor or equivalent surface below the door or sidelight. .

Exceptions: 1. Transparent glass doors and fixed adjacent transparent glass sidelights shall be exempt from the upper area marking requirement (60 to 66 inches above the ground, floor or equivalent surface) if they are provided with horizontal separation bars, muntin bars or equivalent at least one and one-half inches in vertical dimension that extend across the total width of the glazed area and are located at least 40, but not more than 50 inches above the bottom of the door or sidelight.

Historical Note
Sec. added, filed Dec. 21, 1967 to be eff. Jan. 1, 1968.







47.9 Marking dimensions.

The marking design shall be at least four inches in diameter if circular or four inches in its least dimension if elliptical or polygonal, or shall be at least 12 inches in horizontal dimension if the marking is less than four inches in its least dimension. In no event shall the vertical dimension of any marking including lettering be less than one and one-half inches in height.

Historical Note
Sec. added, filed Dec. 21, 1967 to be eff. Jan. 1, 1968.

47.10 Marking methods.

(a) In addition to horizontal muntin bars, separation bars or equivalent, any of the following methods may be used to alert persons to the presence of transparent glass doors and fixed adjacent transparent glass sidelights in their path of movement: .

- | | | |
|---|---|---|
| <p>(1)</p>  <p>chemical etching</p> | <p>(2)</p>  <p>sandblasting</p> | <p>(3)</p>  <p>adhesive strips
not less than one and one-half inches in vertical dimension extending across at least two-thirds of the total glazed area; .</p> |
| <p>(4)</p>  <p>decals</p> | <p>(5)</p>  <p>paint, gilding or other marking materials: .</p> | <p>(6)</p>  <p>opaque door pulls or push bars
extending across at least two-thirds of the total width of the glazed area.</p> |

Historical Note
Sec. added, filed Dec. 21, 1967 to be eff. Jan. 1, 1968.