


N.B. **ALTERATIONS TO LEVEL 4 AND 5** SUBJECT TO FURTHER INSPECTION FROM SAFE PLATFORM WHEN SCAFFOLD IN PLACE AND REPAIR WORK TO LEVEL 3 COMPLETE


94.89



FLOOR ZONE 4 100 % REPLACEMENT INSPECTED BY STRUCTURAL ENGINEER CODE 6 LEAD SHEET PITCH 3 DEGREES, BAY WIDTH 675 MAX SPAN 2250MM ON PLY ON FURRINGS ON SC4 GRADE TREATED TIMBER JOISTS ON 75 X 75 AT 400CNS CNS VARY

FLOOR PLAN LEVEL 4

FLOOR ZONE 3 INSPECTED BY STRUCTURAL ENGINEER 100 % REPLACEMENT 100 % REPLACEMENT 25MM X175 WIDE BOARDS TIMBER BOARDS S/W? ON 60 X 175 6 NUMBER TIMBER JOISTS@450 CNS S/W? BUILT INTO WALL APPROX 80MM BEARING U/S 18MM X 75 WIDE SOFT WOOD CEILING BOARDS




FLOOR PLAN LEVEL 3

CEILING JOIST 170X65 @ 415 CNS RAFTERS 100 X100 CNS AS ABOVE INSPECTED BY STRUCTURAL ENGINEER

3 NUMBER RSJ OVER PARTITION

INSPECTED BY STRUCTURAL ENGINEER ON THE 15/11/12 CONDITION SATISFACTORY



ASSUMED CEILING DEPTH

LEVEL 5

ROOF PLAN 5 100 % DEFECTIVE INSPECTED BY STRUCTURAL ENGINEER ALTERATION DETAILS AS LEVEL 4 REPLACE LOW LEVEL COLLARS

LEVEL 4


FLOOR ZONE 4 100 % REPLACEMENT INSPECTED BY STRUCTURAL ENGINEER
CODE 6 LEAD SHEET PITCH 3 DEGREES,
BAY WIDTH 675 MAX SPAN 2250MM
ON PLY ON FURRINGS ON SC4 GRADE
TREATED TIMBER JOISTS ON 75 X 75 AT 400CNS CNS VARY

LEVEL 3

FLOOR ZONE 3 INSPECTED BY STRUCTURAL ENGINEER 100 % REPLACEMENT
25MM X175 WIDE BOARDS TIMBER BOARDS S/W
ON 60 X 175 (6 NUMBER) TIMBER JOISTS@450 CNS ASSUMED S/W
BUILT INTO WALL APPROX 80MM BEARING
U/S 18MM X 75 WIDE SOFT WOOD CEILING BOARDS

LEVEL 2 FLOOR ZONE 2 ASSUMED DEPTH

SIGN



FLOOR PLAN LEVEL 2

PROPOSED.

SECTION E-E

DATUM LINE 78.00M

WALKER ASSOCIATES ARCHITECTS. **ADDRESS** GODFREY HOUSE NO 17 CHURCH STREET WEEDONNORTHANTS NN74PL TEL/FAX01327340 310 MOBILE0797 985 4896. E-mail walkerarchite **CHARTERED ARCHITECT** LYNNEWALKER B.A.HONS.DIP ARCH. RIBA.

THIS DRAWING IS COPY RIGHT AND MUST NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION FROM WALKER ASSOCIATE ARCHITECTS. DO NOT SCALE ALL DIMENSIONS SHOULD BE CHECKED PRIOR TO THE COMMENCEMENT OF WORKS AND ANY DISCREPANCIES REFERRED TO THE ARCHITECT IMMEDIATELY.

SCALE 1/50 **SPIRE DETAILS** DETAIL. **JOB NUMBER** 3003/LB9

SCALE BAR 3M @ 1.50