



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-1077

Public Water System Bacteriological Report

PWS Name : FORSYTH PWS
Mail to : DAVID D WILLIAMS
14845 US HWY 160
FORSYTH, MO 65653

PWS ID : MO5010285
County : TANEY
Please notify us of any
name and address changes

| | | |
|-------------------------|-----------------------|----------------------|
| Date Collected : | Collector : | Sample Type : |
| 03/26/2025 | WILLIAMS,DAVID | Routine |
| Lab Sample ID : | Location Name: | Location ID: |
| OE1198579 | 165 TOWER STREET | 22 |
| Lab Results : | | |
| A | | |

Coliform absent. Sample considered safe.

| | | |
|-------------------------|-----------------------|----------------------|
| Date Collected : | Collector : | Sample Type : |
| 03/26/2025 | WILLIAMS,DAVID | Routine |
| Lab Sample ID : | Location Name: | Location ID: |
| OE1198580 | 14845 US HWY 160 | 29 |
| Lab Results : | | |
| A | | |

Coliform absent. Sample considered safe.

| | | |
|-------------------------|-----------------------|----------------------|
| Date Collected : | Collector : | Sample Type : |
| 03/26/2025 | WILLIAMS,DAVID | Routine |
| Lab Sample ID : | Location Name: | Location ID: |
| OE1198590 | 249 BLUNK | 30 |
| Lab Results : | | |
| A | | |

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples. If you have any questions about these sample results, call 573-526-0135.

Monday, March 31, 2025