



Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-1077

Public Water System Bacteriological Report

PWS Name : FORSYTH PWS
Mail to : DAVID D WILLIAMS
15405 US HWY 160
PO BOX 545
FORSYTH, MO 65653

PWS ID : MO5010285

County : TANEY

Please notify us of any
name and address changes

Date Collected :	Collector :	Sample Type :
04/14/2025	WILLIAMS,DAVID	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1208327	781 SHADOWROCK	34
Lab Results :		
A		

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Date Collected :	Collector :	Sample Type :
04/14/2025	WILLIAMS,DEVIN	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1208321	1050 SKYLINE DR	32
Lab Results :		
A		

Coliform absent. Sample considered safe.

Date Collected :	Collector :	Sample Type :
04/14/2025	WILLIAMS,DEVIN	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1208322	709 SANTA FE - GARY	13
Lab Results :		
A		

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples. If you have any questions about these sample results, call 573-526-0135.

Thursday, April 17, 2025