



**MISSOURI**  
DEPARTMENT OF  
NATURAL RESOURCES

Public Drinking Water Branch  
P.O. Box 176  
Jefferson City, MO 65102  
(573)526-0135

**Public Water System Bacteriological Report**

**PWS Name :** FORSYTH PWS  
**Mail to :** STEVE MARLER  
15405 US HWY 160  
PO BOX 545  
FORSYTH, MO 65653

**PWS ID :** MO5010285

**County :** TANEY

Please notify us of any  
name and address changes

---

<b>Date Collected :</b>	<b>Collector :</b>	<b>Sample Type :</b>
03/26/2024	MARIE,STEVE	Routine
<b>Lab Sample ID :</b>	<b>Location Name:</b>	<b>Location ID:</b>
OE1007150	112 VIN VILLA ST	24
<b>Lab Results :</b>		
A		

Coliform absent. Sample considered safe.

---

*These sample test results were analyzed by the Missouri State Public Health Laboratory.*

<b>Date Collected :</b>	<b>Collector :</b>	<b>Sample Type :</b>
03/26/2024	MATALN,STEVE	Routine
<b>Lab Sample ID :</b>	<b>Location Name:</b>	<b>Location ID:</b>
OE1007217	188 SANTA FE - JOHN	12
<b>Lab Results :</b>		
A		

Coliform absent. Sample considered safe.

---

*These sample test results were analyzed by the Missouri State Public Health Laboratory.*

**Note to Public Water Systems:**

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples.

*Friday, March 29, 2024*