



Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)526-0135

Public Water System Bacteriological Report

PWS Name : FORSYTH PWS
Mail to : STEVE MARLER
15405 US HWY 160
PO BOX 545
FORSYTH, MO 65653

PWS ID : MO5010285

County : TANEY

Please notify us of any
name and address changes

Date Collected :	Collector :	Sample Type :
05/29/2024	MABLER,STEVE	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1039670	112 VIN VILLA ST	24
Lab Results :		
A		

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Date Collected :	Collector :	Sample Type :
05/29/2024	MARLER,STEVE	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1039671	160 SKYLINE	23
Lab Results :		
A		

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples.

Monday, June 3, 2024