



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Mike Kehoe
Governor

Kurt U. Schaefer
Director

June 4, 2025

Jim Viebrock
Forsyth
P.O. Box 545
Forsyth, MO 65653

LEVEL 2 ASSESSMENT
SANITARY DEFECTS
NO RESPONSE REQUIRED

Dear Jim Viebrock:

On May 28, 2025, a team member from the Missouri Department of Natural Resources conducted an Assessment Level 2 evaluation of the Forsyth public water system (system) located at 15405 US Highway 160, Forsyth, in Taney County. Enclosed is the Level 2 Assessment Form for you to review and keep for your records. During the visit, the following Sanitary Defects were noted:

1. The sample tap at site 18 had debris in it during the original and repeat sampling.

No corrective actions are needed at this time. The system has agreed to discontinue sampling from site 18 unless conditions change at the site.

If you have questions concerning this letter or the form, please feel free to contact Tasha Karpel of this office by calling 417-891-4300, by email at Natasha.Karpel@dnr.mo.gov, or via mail at the Southwest Regional Office, 2040 W. Woodland, Springfield, Missouri 65807-5912.

Sincerely,

SOUTHWEST REGIONAL OFFICE

Gwenda Bassett, Chief
Drinking Water Compliance Unit


GJB/tnk

Enclosures

c: Public Drinking Water Branch, Monitoring Section
Luke Horning, Designated Operator

mo5010285-forsyth-20250604-lv2-taney-dw





MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-1077

Public Water System Bacteriological Report

PWS Name : FORSYTH PWS
Mail to : DAVID D WILLIAMS
15405 US HWY 160
PO BOX 545
FORSYTH, MO 65653

PWS ID : MO5010285

County : TANEY

Please notify us of any
name and address changes

| | | |
|-------------------------|-----------------------|----------------------|
| Date Collected : | Collector : | Sample Type : |
| 05/20/2025 | HORNING,LUKE | Repeat |
| Lab Sample ID : | Location Name: | Location ID: |
| OE1225872 | SAMPLING POINT ID NO | MISSING |
| Lab Results : | | |
| A | | |

Coliform absent. Sample considered safe.

| | | |
|-------------------------|-----------------------|----------------------|
| Date Collected : | Collector : | Sample Type : |
| 05/20/2025 | HORNING,LUKE | Repeat |
| Lab Sample ID : | Location Name: | Location ID: |
| OE1225873 | SAMPLING POINT ID NO | MISSING |
| Lab Results : | | |
| A | | |

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

| | | |
|-------------------------|-----------------------|----------------------|
| Date Collected : | Collector : | Sample Type : |
| 05/20/2025 | HORNING,LUKE | Repeat |
| Lab Sample ID : | Location Name: | Location ID: |
| OE1225962 | 223 CHISHOLM TRAIL | 18 |
| Lab Results : | | |
| P | | |


Sample tested positive for total coliform. This positive sample may require follow up samples to be collected. Please contact your local regional office at 417-891-4300 for further sampling instructions.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples. If you have any questions about these sample results, call 573-526-0135.

Friday, May 23, 2025



MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-1077

Public Water System Bacteriological Report

PWS Name : FORSYTH PWS
Mail to : DAVID D WILLIAMS
15405 US HWY 160
PO BOX 545
FORSYTH, MO 65653

PWS ID : MO5010285

County : TANEY

Please notify us of any
name and address changes

Date Collected : 05/20/2025
Collector : HORNING,LUKE

Sample Type :
Triggered

Lab Sample ID : OE1225940
Location Name: WELL # 1
Location ID: WL 13748

Lab Results :
A

Coliform absent. Sample considered safe.

Date Collected : 05/20/2025
Collector : HORNING,LUKE

Sample Type :
Triggered

Lab Sample ID : OE1225939
Location Name: WELL # 5 - OLD FORSY
Location ID: WL 13752

Lab Results :
A

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples. If you have any questions about these sample results, call 573-526-0135.

Friday, May 23, 2025