





Scientific Justification for Separation Distances in NFPA 2: Hydrogen Technologies Code



Ethan S. Hecht, Brian D. Ehrhart,
and Benjamin B. Schroeder

2025 5th ELVHYS Workshop

June 5, 2025


Previous (2020 edition and before) distances in NFPA 2 for bulk liquid hydrogen storage were large, complex, and lack documentation of basis



Goal: Develop separation distances from bulk liquid hydrogen storage systems that are traceable, defensible, and updatable

Steps (similar to Sandia-led updates for bulk gaseous hydrogen):

1. Verify and validate necessary models
2. Characterize exposure groups and acceptable hazard levels
3. Use quantitative risk assessment to determine characteristic leak size
4. Calculate consequence-based distances using leak size and validated models
5. Get proposed distances approved by building consensus within the technical committee



Previous distances served industry well for half a century but were:



- Based on storage volume
- 75 ft from air intakes
- Different for every exposures (varied within three groups)

The Sandia-developed HyRAM+ toolkit was used for calculations





Available at hyram.sandia.gov, from [PyPI](https://pypi.org/project/hyram/) and [conda-forge](https://conda-forge.org/)

- Fast running, reduced order models
 - Unignited dispersion
 - Flames - trajectory and heat flux
 - Unconfined overpressure
- Behavior models used standalone or for quantitative risk assessment
- Python backend enables flexibility of modeling
- Version 4.1 used for these calculations




The mass flow rate model was updated and compared to data



- HyRAM v4.1 mass flow rate calculations were updated – resulted in increased mass flow for liquid hydrogen
 - No longer relies on uncertain calculation of speed of sound for two-phase fluids
 - Verified by comparing to other models
 - Metastable liquid model (constant density flow instead of isentropic) considered too conservative
- Updated model compares well to data from two experimental campaigns attempting to maximize liquid H_2 flows

Dispersion, heat flux and overpressure models were compared to data



- Very limited number of experimental campaigns
- Mole fractions overpredicted on average, especially in far-field where mole fractions are lower
- Unconfined overpressure greatly overpredicted
- Heat flux criteria distances encompass measurements

Exposures were regrouped for liquid hydrogen



Group 1	1. Lot lines	Should avoid: <ul style="list-style-type: none"> • Harm to the general public • Damage from heat flux • Damage from overpressure • Flammable concentration
	2. Air Intakes	
	3. Operable openings in buildings	
	4. Ignition sources such as open flames/welding	
Group 2	5. Exposed persons other than those servicing the system	Should avoid: <ul style="list-style-type: none"> • Harm to people aware of risk (people at the fueling station) • Significant damage to buildings • Fire spread to ordinary combustibles
	6. Parked cars	
	7. Buildings of combustible construction	
	8. Hazardous materials storage systems above ground or fill/vent openings for below ground storage systems	
Group 3	9. Ordinary combustibles, including fast-burning solids such as ordinary lumber, excelsior, paper, or combustible waste and vegetation other than that found in maintained landscaped areas	Should avoid: <ul style="list-style-type: none"> • Escalation of event (fire spread)
	10. Buildings of non-combustible non-fire-rated construction	
	11. Flammable gas storage systems above or below ground	
	12. Heavy timber, coal, or other slow-burning combustible solids	
	13. Unopenable openings in buildings and structures	
	14. Encroachment by overhead utilities (horizontal distance from the vertical plane below the nearest overhead electrical wire of building service)	
	15. Piping containing other hazardous materials	
	16. Flammable gas metering and regulating stations such as natural gas or propane	

Exposures to consider:

- Air intakes
- Sewer inlets
- People (fireball)

NFPA 2 GH2 uses 8% by volume

- Based on ability to sustain ignition
- Rather than 4% by volume lower flammability limit


NFPA 59A uses lower flammability limit (LFL), or 50% of LFL depending on model used

- Also considers higher concentrations for oxygen displacement

Analysis for LH2 used: 8% by volume unignited concentration for Group 1 exposures




Ignition kernel forms but does not form jet flame



Jet flame is sustained after ignition


Criteria for heat flux were carefully chosen



Analysis for LH2 used:
 4.732 kW/m^2 for Group 1,
 9 kW/m^2 for Group 2, and
 20 kW/m^2 for Group 3

Criteria for peak overpressure were determined

Data from:
[Lobato, Afinidad, 2009](#)
[Huang, IJHE 2018](#)
[Quest Consultants Inc.](#)
[LaChance, IJHE 2011](#)
[Jallais, PSP 2018](#)
[Argo, FPRF 2014](#)
[HSE, 2014](#)



Exposures to consider:

- People
- Cars
- Buildings

Hecht and Ehrhart, ICHS 2021

- Group 1: 0.7 psi
- Group 2: 2.3 psi
- Group 3: 10.2 psi

NFPA 59A Table 19.8.4.3.1

- 3 psi fatality to person outdoors
- 1 psi irreversible harm to person outdoors
- 1 psi limit for buildings

Analysis for LH2 used:

1 psi (7 kPa) for Group 1 exposures,
 2 psi (14 kPa) for Group 2 exposures,
 3 psi (21 kPa) for Group 3 exposures

Basis for a characteristic leak size was informed by quantitative risk assessment



HyRAM+ quantitative risk assessment (QRA) based on


- leak frequency
- ignition probability
- consequence calculations
- fatality probability




Results in risk-based distance from a leak point

- varying QRA inputs can affect this distance significantly


Potential Loss of Life (PLL) Risk Metric at Distances Away from Leak




Sensitivity of Risk-Based Distances



Component Leak Fault Tree



Leak Outcome Event Tree



Sensitivity study enabled selection of a characteristic fractional leak area



QRA varied single input value, then calculated equivalent fractional leak area for a range of system pipe diameters

- **Almost all cases cluster below 5-10%** equivalent fractional hole size
 - **Only 2 of 26 cases exceed 10%** at largest pipe inner diameters
 - **Only 3 additional cases exceed 5%** at largest pipe inner diameters
 - **21 of 26 cases are below 5%** fractional leak area for all inputs and pipe diameters considered

Possibilities considered:


Use 10% hole size as conservative hole size (too conservative)

Use 5% hole size (generally conservative)

Use 3% hole size (mid-range, may not be sufficiently conservative)

**5% of internal flow area
selected as basis**

Selected
leak
size (5%)





Distances are calculated using chosen criteria and models

Calculations for:

- 5% fractional leak area
- 4 characteristic pipe sizes (0.5- 2")
- 3 characteristic pressures for bulk liquid tanks (60-173 psi_g [P_{crit}])


Consequence criteria:

- Group 1:
 - Concentration: 8 mol% (streamline)
 - Heat Flux: 4.732 kW/m² (bird's eye)
 - Peak Overpressure: 6.895 kPa (bird's eye)
- Group 2:
 - Heat Flux: 9 kW/m² (bird's eye)
 - Peak Overpressure: 13.790 kPa (bird's eye)
- Group 3:
 - Heat Flux: 20 kW/m² (bird's eye)
 - Peak Overpressure: 20.7 kPa (bird's eye)
 - Visible Flame Length (bird's eye)



1. Calculate distances for each criteria
2. Select maximum distance within a group for a given pipe size
3. Develop linear correlation for variations in pipe size

Consequence-based calculations for Group 1



Exposures:


1. Lot lines
2. Air intakes
3. Operable openings in buildings
4. Ignition sources such as open flames/welding

Protects against:

- Flammable concentration
- Damage from heat flux
- Damage from overpressure
- General public

**Distance to 8% mole fraction
drives setback distance**

Consequence-based calculations for Group 2



Distance to 9 kW/m² heat flux drives setback distance


Exposures:

- Exposed persons other than those servicing the system
- Parked cars
- Buildings of combustible construction
- Hazardous materials storage systems above ground or fill/vent openings for below ground storage systems
- Ordinary combustibles, including fast-burning solids such as ordinary lumber, excelsior, paper, or combustible waste and vegetation other than that found in maintained landscaped areas

Protects against:

- Fire spread to ordinary combustibles
- Significant damage to buildings
- Harm to people informed of risk (people at the fueling station)

Consequence-based calculations for Group 3



Distance to 20 kW/m² heat flux drives setback distance

Exposures:

10. Buildings of Non-combustible non-fire-rated construction
11. Flammable gas storage systems above or below ground
12. Heavy timber, coal, or other slow-burning combustible solids
13. Unopenable openings in buildings and structures
14. Encroachment by overhead utilities (horizontal distance from the vertical plane below the nearest overhead electrical wire of building service)
15. Piping containing other hazardous materials
16. Flammable gas metering and regulating stations such as natural gas or propane

Protects against:

- Escalation of event (fire spread)

Distances were tabulated for a typical and range of pipe sizes



- Single distance for each exposure group and pressure
- Pressure ranges do not show large differences, but may be useful in some cases
- Pipe size can significantly affect distances

Table 8.3.2.3.1.6(a) Minimum Distance from Outdoor Bulk Liquefied Hydrogen (LH₂) Systems to Exposures, Up to 75,000 gal (280,000 L) — Typical Inner Diameter (*d*) 1.5 in. (38.1 mm)

Maximum Operating Pressure (MOP) (gauge)	<60 psi (<414 kPa)		60 to 120 psi (414 kPa to 827 kPa)		>120 psi (>827 kPa)	
	ft	m	ft	m	ft	m
Exposures Group 1						
1. Lot lines						
2. Air intakes (e.g., HVAC, compressors)						
3. Operable openings in buildings and structures	44	13.3	48	14.5	49	14.9
4. Ignition sources such as open flames and welding						
Exposures Group 2						
5. Exposed persons other than those servicing the system						
6. Parked cars						
7. Buildings of combustible construction						
8. Hazardous materials storage systems above ground or fill/vent openings for belowground storage systems	31	9.4	36	11.1	38	11.6
9. Ordinary combustibles, including fast-burning solids such as ordinary lumber, excelsior, paper, or combustible waste and vegetation other than that found in maintained landscaped areas						
Exposures Group 3						
10. Buildings of noncombustible non-fire-rated construction						
11. Flammable gas storage systems above or below ground						
12. Heavy timber, coal, or other slow-burning combustible solids						
13. Unopenable openings in buildings and structures	26	8.0	31	9.5	33	10.0
14. Encroachment by overhead utilities (horizontal distance from the vertical plane below the nearest overhead electrical wire of building service)						
15. Piping containing other hazardous materials						
16. Flammable gas metering and regulating stations such as natural gas or propane						

Table 8.3.2.3.1.6(b) Minimum Distance from Outdoor Bulk Liquefied Hydrogen (LH₂) Systems to Exposures by Inner Diameter (*d*)

Maximum Operating Pressure (MOP) (gauge)		<60 psi (<414 kPa)						60 psi to 120 psi (414 kPa to 827 kPa)						>120 psi (>827 kPa)					
		Group 1		Group 2		Group 3		Group 1		Group 2		Group 3		Group 1		Group 2		Group 3	
Inner Diameter (<i>d</i>)		0.34 <i>d</i> + 0.24		0.20 <i>d</i> + 1.84		0.15 <i>d</i> + 2.08		0.37 <i>d</i> + 0.53		0.24 <i>d</i> + 1.96		0.19 <i>d</i> + 2.19		0.38 <i>d</i> + 0.57		0.25 <i>d</i> + 1.93		0.20 <i>d</i> + 2.16	
in.	mm	ft	m	ft	m	ft	m	ft	m	ft	m	ft	m	ft	m	ft	m	ft	m
0.5	12.7	15	4.7	14	4.2	13	4.0	18	5.4	16	4.8	15	4.5	18	5.5	16	5.0	15	4.6
1.0	25.4	29	8.9	23	7.0	20	6.1	32	9.7	27	8.1	23	7.1	33	10.0	28	8.5	24	7.5
1.5	38.1	44	13.3	31	9.4	26	8.0	48	14.5	36	11.1	31	9.5	49	14.9	38	11.6	33	10.0
2.0	50.6	58	17.8	38	11.7	32	9.8	63	19.3	45	13.8	38	11.6	65	19.9	48	14.6	41	12.3

(1) Linear interpolation of internal pipe diameters and distances between table entries is allowed.




(2) For a list of exposures in each exposure group, see column 1 of Table 8.3.2.3.1.6(a).

(3) When calculating the minimum separation distance using the formulas indicated, based on the exposure group and pressure indicated, the inner diameter (*d*) is entered in millimeters (mm). The calculated distance is returned in units of measure in meters (m). To convert distance to units of measure in feet, multiply the value in meters by 3.2808 and round to the nearest whole foot.

Updated distances are smaller in some cases, but larger in others




- Distances are most often reduced for group 1 exposures
- Distances for group 3 exposures are increased in many cases



Credits for insulated piping and fire barrier walls remain

- Fire barrier walls reduce dispersion, heat flux, and overpressure
 - Fire barrier walls allow the reduction of distances in Groups 1 and 2 by 50% (including air intakes)
 - Fire barrier walls enable Group 3 distances to be reduced to 0 ft
- Vacuum insulated piping reduces propensity for leaks due to double walls and welded joints
 - Distances to exposures can be reduced by 2/3 for vacuum-insulated lines with no mechanical connections, joints, or leak sources
- An Emergency Shutdown System is required for all public refueling systems



Tests on mitigation from fire barrier walls for gaseous hydrogen flames. From [Schefer et al. IJHE 2008](#).


Acknowledgements and collaboration



- This work was part of the NFPA 2 Storage Task Group
 - Part of the Hydrogen Technologies Technical Committee
- This work was supported by the U.S. Department of Energy (DOE) Office of Energy Efficiency and Renewable Energy (EERE) Hydrogen and Fuel Cell Technologies Office (HFTO)
 - Part of the Safety Codes and Standards sub-program under the direction of Laura Hill
- Special thanks to task group members for input, direction, discussion, verification, and reviews:
 - David Farese (formerly Air Products, now Durham Consulting LLC)
 - Derek Miller (Air Products)
 - Thomas Drube (Chart Industries)
 - Mukesh Trivedi (Chart Industries)
 - John Anicello (Chart Industries)
 - Dusty Brooks (Sandia National Laboratories)
 - Jamal Mohmand (formerly at Sandia National Laboratories, now at Lockheed Martin)
 - Chris LaFleur (Sandia National Laboratories)

Summary and future work

- Updated distances are simplified, defensible, and well-documented
- Enables assumptions to be changed and incremental improvements to be made
- Framework could be applied to other setback distances in the future (gaseous setbacks could be revisited)
- Larger systems still need science-based codes and standards (separation distances are currently unspecified for systems larger than about 20 metric tons)
- Additional studies of mitigations from fire barrier walls specific to liquid hydrogen dispersion and flames are needed



Full report available:
[SAND2023-12548](#)



**Latest HyRAM+ updates and links to
additional documentation at**
hyram.sandia.gov



Thank you!


Questions?

ehocht@sandia.gov



hram.sandia.gov

Reduced footprint is enabled by updated tables and language in NFPA 2



Characteristic	NFPA 2 (2016)	NFPA 2 (2023)
Assumed system	3,500-15,000 gal [950 - 4000 kg] tank	Same tank, 1.5" diameter piping, >120psi
Distance to air intakes	75 ft (unable to reduce with walls)	24'-6" (49 ft reduced by half due to barrier wall)
Lot lines	16.7' (50 ft, reduced by 2/3 due to insulation)	24'-6" (49 ft reduced by half due to barrier wall)
Gaseous portion of system	Same separation distances as liquid system	Treated separately, divided by source valve (changed in 2020 version of NFPA 2)
Driver of separation distance to building	Air intakes	Distance to building /parking spaces (19 ft - group 2 exposure [38 ft reduced by half due to barrier wall])