

EASY JOINT/ YES COLOUR TEST REPORT

SCOPE OF WORK

WPC DECKING

REPORT NUMBER

190722010SHF-001

TEST DATE(S)

2019-07-23 - 2019-08-12

ISSUE DATE

2019-08-12

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2019 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date: 2019-08-12 Intertek Report No. 190722010SHF-001
Applicant: ZHEJIANG TIMBER NEW MATERIAL CO., LTD. NO.190 NORTH HUANCHENG ROAD,
Address: DEQING INDUSTRIAL ZONE, ZHEJIANG, CHINA Xiaolei Wu Performance test, samples
Attn: provided by the applicant.
Test Type:

Product Information

Product Name	WPC DECKING Good Condition	Brand	U-TIMBER
Sample		Sample Amount	8 pieces
Description		Received Date	2019-07-12
Sample ID	Model	Specification	
S190722010SHF.001	150H25	/	

Test Methods And Standards

Test Standard	AS 4586-2013 Appendix D
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized



Flora Fan Jackie Zhou
 Name: Flora Fan Name: Jackie Zhou
 Title: Reviewer Title: Project Engineer

Test Report

Issue Date: 2019-08-12

Intertek Report No. 190722010SHF-001

Test Items, Method and Results:

Test item	Test Method	Test result
Oil-wet inclining platform test*	AS 4586-2013 Appendix D	Angle: 19.8 ° Rating: R11

Classification of Pedestrian surface materials according to the oil-wet inclining platform test

Classification	Angle, degrees
No classification	<6
R9	$6 \leq X < 10$
R10	$10 \leq X < 19$
R11	$19 \leq X < 27$
R12	$27 \leq X < 35$
R13	≥ 35

Note:


- *Test item is subcontracted on accreditation by CNAS L1401.

Test Report


Issue Date: 2019-08-12

Intertek Report No. 190722010SHF-001

Appendix A: Sample Received Photo



Front View(Test surface)



Back View



Section view

Revision:

NO.	Date	Changes	Author	Reviewer
190722010SHF-001	2019-08-12	First issue	Jackie Zhou	Flora Fan