

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
PURBA MEDINIPUR DIVISION
WEST BENGAL FIRE & EMERGENCY SERVICES
TAMLUK, PURBA MEDINIPUR



Memo No.: WBFES/PBM/.. 982/21

Dated: 4-9-21

From : The Divisional Fire Officer
Purba Medinipur Division
West Bengal Fire & Emergency Services
To : Mr. Sekhar Bera
Secretary of ODALCHUA PTTI & B.ED. COLLEGE
Organized by Jukhia Netaji Academy society
Vill+P.O.- Jukhia Bazar, P.s. – Bhupatinagar
Dist. – Purba Medinipur

Sub : - Renewal Fire & Life Safety Certificate of Existing G+1 & G+2 Storied under group of Educational Building in the Name & Style ODALCHUA PTTI & B.ED. COLLEGE at Jukhia Bazar, P.s. – Bhupatinagar, Dist. – Purba Medinipur, Plot No. – 46 & 47, J.L No. – 240. Khatian No. – 835, LR Khatian No. – 1077.

Sir,

This is reference to your letter No. – Nil, dated – Nil regarding Renewal Fire & Life Safety Certificate of Existing G+1 & G+2 Storied under group of Educational Building in the Name & Style ODALCHUA PTTI & B.ED. COLLEGE at Jukhia Bazar, P.s. – Bhupatinagar, Dist. – Purba Medinipur, Plot No. – 46 & 47, J.L No. – 240. Khatian No. – 835, LR Khatian No. – 1077.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is hereby releasing the 'Fire Safety Certificate' for the aforesaid building.

However to up-keep the Fire Safety measure of the aforesaid building the following safety measures are to be incorporated.

1. Driveway must be free of any type of obstruction for Easy movement of Fire Appliances No parking will be allowed on the Driveway.
2. Directional sign and escape route shall be displayed prominently.
3. To eliminate risk of fire Hazards. Good house keeping both for inside and out side of the building shall be strictly maintained.
4. The interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
5. The notice of Fire Fighting and Evacuation with "Exit Sign" from the building shall be prepared and displayed at all vulnerable places of the Building before taking occupancy.
6. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
7. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.





8. First-Aid Fire Fighting System shall be provided as per I.S. specification.
9. Arrangement shall have to be made for regular checking, testing and maintenance Of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
10. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
11. Periodical flashing of water from the Hydrants and Hose Reel hose pipe line shall be made to maintain the efficient working performance of above mentioned system.
12. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
13. Existing Electrical wiring of the whole building shall have to be carefully checked for any where and tear in theme, particularly lines above false ceiling & ducts.
14. A Fire control room including a close circuit T.V. system will have to be installed which will observe all the floor of the building.
15. Transformer and switch gear room shall be protected with automatic CO² or D.C.P. Fire Extinguisher conforming I.S. Specification.
16. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
17. This N.O.C. is valid for one year and have to be renewed every year from the date of issue of this letter.
18. Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the life & Fire Safety arrangements and installation of the buildings.
19. No Addition & Alteration without prior permission of West Bengal Fire & Emergency Services, other wise the Fire Safety Certificate will be treated as cancelled.

21/5/21
Divisional Fire Officer
Purba Medinipur Division
West Bengal Fire & Emergency Services

Divisional Fire Officer
Purba Medinipur Division
W.B. Fire & Emergency Services



SURAKHA ENTERPRISE

All kinds of Fire Extigusher & Equipments Suppliers
Sitapur :: Daspur :: Paschim Medinipur



Supplier Reg. No-G/R-254 / 16-7
Daspur-II

PAN No-AQBPG5739P
Income Tax Return NO. 12050 at Haldia

Order No.

Refill Date

30.08.21


Test Certificate

TO WHOM IT MAY CONCERN

This is to we have Refilled.....12 nos..... Fire Extinguishess To.....Odalchua PTTI & Co.
Colgoge Vill. Jukhia Bazar P.O. Bhupatinaga
Dist. Purba Medinipur..... of FIRE CON band ISI Mark Extiguishes.

Types of Fire Extinguish	Capasity	Quantity
Dry Chemical Powder D.C.P.	5kg	10 nos
water Co ₂	945	one
Co ₂ tipe	2kg	one

This is also to certifie that we shall stand guarantee of its good services for a period of 30.8
29.8.21 year. from the date of Refill and in case of my extiguisher defect found we shall replace th
same free at our own cost.



Signature

SURAKHA ENTERPRISE

All kinds of Fire Extinguisher & Equipments Suppliers
Sitapur :: Daspur :: Paschim Medinipur



Order No. Refill Date 30.8.21 ... Supply Date.
Name Odaichua PTT & B.S.D. Col. ex.
Address Jukhaia Bazar, Purba Medinipur

Description	Capacity	Quantity	Rate	Amount
1) Dry Chemical powder	5kg	10 nos	200/-	2000/-
2) water Co2	945	one	200/-	200/-
3) Co2 type	2kg	one	200/-	200/-
TOTAL Rs.				2400/-

in words, Ruppes

Two thousand four hundred only




Signature [Signature]
SURAKHA ENTERPRISE
Sitapur :: Daspur :: Paschim Medinipur



पश्चिम बंगाल WEST BENGAL
BEFORE THE NOTARY PUBLIC, AT HALDIA, PURBA MEDINIPUR. 07AB 797587
Sl. No. 1135/V
On dated 15.5.

AFFIDAVIT


I, Supratim Bera S/O:- Sekhar Bera, of Vill- Jukhia, P.O-Jukhia Bazar, P.S-Bhupatinagar, Dist-Purba Medinipur, West Bengal, Pin-721430. Owner of Odalchua PTTI & B.Ed. College, organized by Jukhia Netaji Academic Society at Banimandir Bus Stop, Vill+P.O-Jukhia Bazar, P.S-Bhupatinagar, Dist-Purba Medinipur, West Bengal, Pin- 721430. am stating that all recommendations of Fire Safety will be complied within three months. I take responsibility, if any untoward problems occurs during the period.
That all the statements are true to the best of my knowledge and belief.



Deponent is identified and Signed the Affidavit on Oath before me

On this 15th day of May 21

Pradip Kumar Jana, NOTARY
Notarized by Govt. of West Bengal
No. 53 of 1952
Dist-Purba Medinipur



(Supratim Bera)
Signature of the Deponent.
Identified by me Signed in my presence.

Advocate : Haldia
15/5/21