

Microanalysis of Well # 2 Water Report # 11712156

1. Bacteria

Bacteria Found Similar to
Burkholderia cepacia
Total Colony Count = 112,000 CFU/100mL

2. Fungi (Including Mold and Yeast)

No Fungi Growth

3. Particles

Large Quantity of Sand and Mineral Sediment Found
Iron Bacteria Found Similar to
Sphaerotilus natans
Particle Count = 270 particles/mL

¹ cfu/ml = colony forming units per milliliter

² TNTC = Too numerous to count = > 160,000 cfu/100mL

³ Additional information regarding the organism(s) detected in this analysis can be attained using resources such as the Internet, local libraries, or by consulting your physician.

The integrity of the sample and results are dependent on the quality of the sampling. The results apply only to the actual sample tested. ETR Labs Inc. shall be held harmless from any liability arising out of the use of such results.