TOBIQUE SPORTS PARK Phase 2 - Buildings Tobique First Nations, NB New Construction Dossier EVOQ 9223-18-00

## **ADDENDUM A-04**

June 21, 2022

Page 1 of 3

THE FOLLOWING MODIFICATIONS, ADDITIONS, DELETIONS, CLARIFICATIONS AND/OR INFORMATION ARE HEREBY MADE A PART OF THE TENDER DOCUMENTS AND SHALL BE FULLY BINDING AND ARE EFFECTIVE IMMEDIATELY.

# 1. ANSWERS TO QUESTIONS

**1.1 Question:** Foodservice subcontractor: after reviewing this project and they need confirmation that the products are required for section 11 40 10 which is missing from the Technical Specs. There is a list of products only listed on drawing A-003 but are listed as Food Service Stock Equipment. Is this equipment that they currently have and will be used in the project or is this to be purchased as part of this tender? If we are to provide 11 40 10, please provide specifications.

**Answer:** The owner has no kitchen supplies and equipment, and the purchase of such supplies and equipment is a part of the tender. All the specifications are found on drawing A003 Specifications under the section 10 28 10 Washroom and other accessories 3. Canteen Accessories and Section 11 40 10 – Food Service Stock Equipment. **Please note that the Architectural Specifications are found on drawings A-001-A003.** 

**1.2 Question:** Is it acceptable to go with 4mm/.060/4mm tempered laminated inside and out of the sealed units for this project? One of the suppliers is noting they are unable to go smaller than that. It would end up creating a smaller airspace on the sealed unit. Please clarify.

Answer: 4mm tempered glass is acceptable while maintaining a 1.5mm distance between layers of glass.

**1.3 Question:** Spec sections listed in the *Table of Content 00 01 10* are missing from the *Technical Specs* (please provide), the following are missing:

Section 03 35 00

Section 05 50 00

Section 06 10 00

Section 06 20 00

Section 06 40 00

All Division 7 (except 07 21 13 is provided)

All Division 8

All Division 9

All Division 10

Section 11 40 10

Section 12 50 00

All Division 31 (except 31 66 15)

Section 31 11 16.01, 32 11 23, 32 15 60, 32 31 13, 32 93 23

All Division 33

Answer: Please note that the Architectural Specifications, all sections listed below are found on drawings A-001-A003:

Section 03 35 00

Section 05 50 00

Section 06 10 00

Section 06 20 00

Section 06 40 00

All Division 7 (except 07 21 13)

All Division 8

TOBIQUE SPORTS PARK Phase 2 - Buildings Tobique First Nations, NB New Construction Dossier EVOQ 9223-18-00

## **ADDENDUM A-04**

June 21, 2022

Page 2 of 3

All Division 9 All Division 10 Section 11 40 10 Section 12 50 00

Division 31 (except 31 33 13 and 31 66 15) and Division 33 Specifications are to be removed from this tender.

**1.4 Question:** Regarding aluminum doors, frames and windows (section 08 11 16, 08 50 50), can equal products from Anotec, Alumicor, or Kawneer also be acceptable?

**Answer:** Please refer to A-01 Item 1.1. Anotec Manufacturing Inc. Fixed and Projected Heavy Duty Insulated Window, Series 80 has been accepted as an equivalent product. Item 1.2 Anotec Manufacturing Exterior Aluminum Frames has been accepted as an equivalent product. Please refer to this Addendum, Item 2.2. to see the accepted equivalent products for aluminum doors and frames.

- If, Alumicor or Kawneer products are to be considered as equivalencies, spec sheets for exact products and guarantees must be provided to be reviewed.
- **1.5 Question:** Building section 2 A-401b references 2 A551 along gridline 3. This detail shows a structural steel member above the coiling door at equipment rental. This is not indicated on the structural drawings, please provide further details.

**Answer:** The structural members on line 3 are all detailed on the structural drawings S1B and S2B. The contractor shall use these structural drawings for these wood members that consist of a continuous 228 mm x 406 mm at roof beam, a 44 x 406 lintel type L6 above the coiling door at canteen and a 38 x 140 mm wood bearing wall type WL1 between these two beams c/w specific gang studs type G1 aligned with the 137 x 406 roof beams.

## 2. REQUEST FOR PRODUCT EQUIVALENCY

# 2.1. Floor Grating

**Specification section 10 28 20 Floor Grating**, issued in tender documents: **Bolar BA-1** or approved equivalent,

**Accepted Equivalency: Pedigrid G8** Serrated aluminum with LB frame and pan. Aluminum -ASTM B221 alloy 6105-T5 for rail extrusions and 6061-T6 aluminum alloy.

#### 2.2. Aluminum Doors

 Specification section 08 11 16, Aluminum doors and frames, issued in tender documents: Exterior Doors: Product 2750 by Prévost Architectural, or approved equivalent, Interior Doors: Product 2700 by Prévost Architectural, or approved equivalent. Door thickness 51mm, ASTM B221, thickness of extruded aluminum 3,0mm min. Interior aluminum frames: Product 65 Series by Prévost Architectural or approved equivalent. Product: A.D. Prévost 3400 REG or approved equivalent.

Accepted Equivalency: Interior and Exterior Doors: Anotec Manufacturing Inc. Swing door Series 22

**TOBIQUE SPORTS PARK** Phase 2 - Buildings Tobique First Nations, NB **New Construction** 

Dossier EVOQ 9223-18-00

## **ADDENDUM A-04**

June 21, 2022

Page 3 of 3

and Series 23 (6063-T5 alloy and temper) Clor: Clear anondized.

Accepted Equivalency: Interior and Exterior Doors: Windspec Series 500 and HTP 500.

Accepted Equivalency: Interior Aluminum frames: Anotec Manufacturing Inc. Flushed Framed Framing

Series 60.

Accepted Equivalency: Interior Aluminum frames: Windspec series 630. Accepted Equivalency: Curtain wall: Windspec 5500HTP series curtain wall.

#### 2.3. Washroom Accessories

Specification section 10 28 10, issued in tender documents:

**AC01:** Bobrick B-2013 AC02: Bobrick B-165 AC03: Bobrick B-4288

AC04: Dyson Airblade V AC05: Bobrick B277

AC06: Bobrick B-270 AC07: Bobrick B-5806 AC08: Bobrick B-5806

AC09 Koala Kare KB110-SSWM

AC10: ASI 7382

# **Accepted Equivalency:**

AC01: Bradley Model 6A01-11 Surface Mounted Foam Tank Vertical

AC02: Bradley Mirror with roll-formed channel frame and theft-resistant mounting

Standard Model 781-2436 (24" x 36")

AC03: Bradley Model 5A10-11 - Surface Mounted Toilet Tissue Dispenser

AC04: Same as specified Dyson Airblade V

AC05: Bradley Model 3565 – Surface mounted Waste Receptacle

AC06: Bradley Model 4A10-11 Surface Mounted Sanitary Product Disposal Unit

AC07: Bradley 832 Grab Bar 001-24" and 001-36" AC08: Bradley 832 Grab Bar 001-24" and 001-36"

AC09: Bradley 962 Stainless Steel Baby Changing Station

AC10: Bradley Accessories 9134 Hat and Coat Hook

# 2.4. Playground Structure

ABC Recreation play structrures have not been approved due to dissatisfaction with the product and service from a previous project.

**END OF ADDENDUM A-04**