



Basic Swimming Pool Barrier Compliance Checklist

RHY

CERTIFIERS

Use this quick checklist to identify some of the common requirements for a compliant swimming pool barrier against AS1926.1-2012. It is designed as a helpful guide for all.



Please note: This checklist is a general guide only and does not replace a formal inspection by a registered swimming pool inspector. Not all compliance requirements are included in this checklist, and additional requirements may apply to your pool and property.

Barrier height Pool barrier is at least 1.2 m high (measured from the finished ground/floor level).	☐
No climbable objects There are no climbable objects, furniture, pot plants, retaining walls or structures within the required non-climbable zone around the barrier.	
	☐
Gaps under the barrier Gaps underneath the barrier are less than 100mm and cannot allow a child to pass underneath.	
	☐
Fence openings Openings in the barrier are less than 100mm wide to prevent a child from passing through.	☐

Basic Swimming Pool Barrier Compliance Checklist

RHY

CERTIFIERS

Boundary fence Where a boundary fence forms part of the pool barrier, it meets the required height of 1800mm.	
	☐
Pool gate The gate opens away from the pool area and is self-closing and locking.	☐
Latch height The gate latch is positioned minimum 1500mm high and/or protected with required dimensions.	
	☐
CPR sign A compliant CPR sign is clearly displayed in a legible location.	☐

RHY Certifiers

Ryan Hu +61 425 207 050
ryan@rhycertifiers.com.au
rhycertifiers.com.au



This checklist is a general guide only and does not replace a formal swimming pool barrier inspection. Pool barrier requirements can vary depending on the age of the pool, property, barrier and applicable legislation/standards. Additional requirements may apply to your property.