



GENERAL NOTES

Precast concrete shall be exposure Class S and meet min compressive strength of 35MPA

Cement: Type GU
Air Category: 4.0% - 7.0%
Aggregate: CSA/CAN A23.4
Maximum Size: 20mm
Admixtures: CSA/CAN A23.4
Reinforcing: Grade 400W CSA G30.18-09
Inserts/Embeds: As noted in drawing details

Manufacture of precast concrete units shall be in accordance with specification CSA A23.4

** LEKO PRECAST LTD SHALL NOT BE RESPONSIBLE FOR ANY INSTALLATION PRACTICES FOLLOWED ON-SITE UNLESS PERFORMED BY LEKO PRECAST LTD **

Tank Weight 5,250kg (11,575lbs)
Lid Weight 1,315kg (2,900lbs)
Assembled Weight 6,565kg (14,475lbs)

Unit Designed to Meet H-20 loading.

Unit manufactured with concrete baffles as shown.

Vent holes available upon request.

Ladder rungs available upon request.

Unit supplied with polypropylene Q-Pac coalescing media as shown.

Maximum Flow Rate - 9.0 L/sec.

Maximum Capacity: 2100L (2.1m³).

4 -4T lifters installed as shown.



TYPE II OIL INTERCEPTOR

DRAWN BY: JA	CHECKED BY:	APPROVED BY:	DATE: February 2019
ASSEMBLY DWG.	PREVIOUS DWG.	DRAWING NO.	REVISION
SCALE: 1:25	ISOMETRIC: N/A	0116	4
DO NOT SCALE THIS DRAWING			