



GENERAL NOTES

Manufacture of precast manhole barrels shall be in accordance with CSA A23.1/A257 and ASTM C478 specifications

Concrete shall be exposure Class HSe and meet min compressive strength of 30MPa @ 28d

Air Category: 4.0% - 7.0% (except where zero-slump concrete is used)

Aggregate: CSA/CAN A23.4
Maximum Size: 20mm

Admixtures: CSA/CAN A23.4
Reinforcing: Grade 400W CSA G30.18

Inserts/Embeds: As noted in drawing details

Lifting Apparatus: 4x 4T Starcon anchors

*** LEKO PRECAST LTD SHALL NOT BE RESPONSIBLE FOR ANY INSTALLATION PRACTICES FOLLOWED ON-SITE UNLESS PERFORMED BY LEKO PRECAST LTD **

Meets H-20 Loading

4165Kg (9160 LBS)



96" (2440mm) MANHOLE LID w/30" (760mm) OPENING

DRAWN BY: JP		CHECKED BY:		APPROVED BY:		DATE: JUNE 2024	
ASSEMBLY DWG.		PREVIOUS DWG.		DRAWING NO. M9621			REVISION 6
SCALE: 1:30		ISOMETRIC: 1:30					
DO NOT SCALE THIS DRAWING							