



**GENERAL NOTES**

Precast concrete shall be exposure Class S and meet min compressive strength of 35MPA

Cement: Type GU  
 Air Category: 4.0% - 7.0%  
 Aggregate: CSA/CAN A23.4  
 Maximum Size: 20mm  
 Admixtures: CSA/CAN A23.4  
 Reinforcing: Grade 400W CSA G30.18-09  
 Inserts/Embeds: As noted in drawing details

Manufacture of precast concrete units shall be in accordance with specification CSA A23.4

**\*\* LEKO PRECAST LTD SHALL NOT BE RESPONSIBLE FOR ANY INSTALLATION PRACTICES FOLLOWED ON-SITE UNLESS PERFORMED BY LEKO PRECAST LTD \*\***

Tank Volume 1,210igal (786/421)  
 Tank Weight 4,497Kg (9,914 lbs)  
 Lid Weight 1,391Kg (3,066 lbs)  
 Total Weight 5,888Kg (12,980 lbs)



**1250IG 2 COMPARTMENT SEPTIC TANK**

DRAWN BY: JA	CHECKED BY:	APPROVED BY:	DATE: June 2022
ASSEMBLY DWG.	PREVIOUS DWG.	DRAWING NO. S0205	REVISION 6
SCALE: 1:50 ISOMETRIC: 1:50			
DO NOT SCALE THIS DRAWING			