

GENERAL NOTES:

- 1. General Arrangement drawings only. Contact Hydro International for site specific fabrication drawings.
- 2. The maximum diameter of the inlet & outlet pipes is 30". For pipes larger than 30", please contact Hydro International for additional design assistance.
- 3. Multiple inlet pipes possible (refer to project plans).
- 4. Inlet/outlet pipe angle can vary to align with drainage network (refer to project plans).
- 5. Peak flow rate and minimum height limited by available cover and pipe diameter.
- 6. Larger sediment storage capacity may be provided with a deeper sump depth.

PRODUCT SPECIFICATIONS:

- A. The treatment system shall use an induced vortex to separate pollutants from stormwater runoff.
- B. The treatment system shall fit within the limits of excavation (area and depth) as shown in the project plans and will not exceed the dimensions for the design flow rates specified herein.
- C. The treatment system shall remove greater than or equal to 90% of TSS based on the Target Particle Size (TPS) of 106 microns and/or 80% of TSS based on the TPS of 230 microns at 2.2 cfs and 3.8 cfs, respectively.
- D. The treatment system shall convey the Peak On-line Flow Rates of up to 32 cfs without causing upstream surcharge conditions. Full-scale independent laboratory scour testing shall demonstrate effluent control of less than or equal to 5 mg/L for all flows up to 200% of MTFR-106.
- E. The treatment system shall be capable of capturing and retaining fine silt and sand size particles. Analysis of captured sediment from full-scale field installations shall demonstrate particle sizes predominately in the 20-micron range

Notes

- 1. MANHOLE WALL AND SLAB THICKNESSES ARE NOT TO SCALE. 2. CONTACT HYDRO
- 2. CONTACT HYDRO
 INTERNATIONAL FOR A
 BOTTOM OF STRUCTURE
 ELEVATION PRIOR TO
 SETTING FIRST DEFENSE
 MANHOLE.
- 3. CONTRACTOR TO CONFIRM RIM, PIPE INVERTS, PIPE DIA. AND PIPE ORIENTATION PRIOR TO RELEASE OF UNIT TO FABRICATION.

RC	1/15/15	FIRST ISSUE
REVIBY	DATE	DESCRIPTION

REVISION HISTORY

Date	Scale
11/25/14	1/4" = 1'0"

Drawn	Checked	Approved
RC		

Title

6-FT DIAMETER FIRST DEFENSE

HIGH CAPACITY
GENERAL ARRANGEMENT



Stormwater Solutions 94 Hutchins Drive Portland, Maine 04102 Tel: (207) 756-6200 Fax: (207) 756-6212 stormwaterinquiry@hydro-int.com

CAD Ref: F6HC-MAX

Project No. xx-xxxx

Drawing No. F6HCS1 Rev.

SIZE ITEM in (mm) DESCRIPTION 72 (1828) I.D. PRECAST MANHOLE 1 2 LEDGER SUPPORT 3 SEPARATION MODULE 30 (762) INLET PIPE (BY OTHERS) 4 5 30 (762) OUTLET PIPE (BY OTHERS) 30 (762) FRAME AND COVER (OR GRATE) (ROUND) 6

Parts List

© 2008 Hydro International

Inlet pipe(s) can

enter anywhere

within 240° arc.

Any warranty made by Hydro International only applies to those items supplied by it. Hydro International does not accept and expressly disclaims any responsibility or liability for any structure, plant or equipment (or the performance thereof) designed, built, manufactured or supplied by any third-party. Hydro International has a policy of continuous product development and reserves the right to amend the specifications of any of its products or equipment at any time. Hydro International expressly disclaims any liability for the performance of its equipment (or any part thereof) used or made subject to conditions outside of the conditions expressly disclaims any liability for the performance of its equipment (or any part thereof) used or made subject to conditions outside of the conditio