






Subject	Catch Basin #7 along 24/26 Talcott. Sediment approximately 3-1/2 below invert. Approximately 15 inches of sediment.	1
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		
Subject	Manhole #5, backyard of 19 Talcott. Structure receives flow from both cul-du-sacs. Clean - no sediment.	2
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #4, backyard of 67 Talcott. Needs topsoil around structure.	3
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		

Subject	Catch Basin #4, 67 Talcott. Sediment 8 inches below invert. Approx 30 inches sediment.	4
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Manhole #7, along 44/46 Talcott. Fence owned by 44 Talcott constructed over manhole.	5
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		
Subject	Catch Basin #14, along 46/48 Talcott. Clean, no sediment.	6
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #14, along 46/48 Talcott. Clean, no sediment.	7
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #25 backyard of 48 Talcott.	8
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Catch Basin #25 backyard of 48 Talcott. Dry sediment 3 inches below invert. Approx 13 inches sediment at thickest point.	9
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #2. Fence along 42/44 Talcott built over catch basin, owned by 44 Talcott	10
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #2, 44 Talcott. Sediment 4 inches below invert. Approx 13 inches sediment.	11
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		
Subject	44/46 Talcott. Manhole #7. Removable fence owned by 44 Talcott overlies structure.	12
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	44/46 Talcott. Manhole #7. Clean, no sediment, few rocks.	13
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	44/46 Talcott. Manhole #7. Clean, no sediment, few rocks.	14
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Manhole #12 behind 75 Talcott.	15
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		
Subject	Manhole #12 behind 75 Talcott. Approximately 1/8 inch of sediment in invert.	16
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Manhole behind 77/81 Talcott.	17
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Manhole behind 77/81 Talcott. No sediment.	18
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #18 on west side of subdivision entrance at Crystal Lake Ave, behind 4 Talcott.	19
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Catch Basin #18, clean, no sediment.	20
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Monumentation on west side of entrance, westernmost section. Missing plate on monument.	21
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Monumentation on west side of entrance, west-central section.	22
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Monumentation on west side of entrance, east-central section.	23
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		
Subject	Monumentation on west side of entrance, northeasternmost section.	24
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Monumentation on east side of entrance, west-central section.	25
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		

Subject	Monumentation on east side of entrance, east-central section.	26
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Monumentation on east side of entrance, east-central section.	27
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Monumentation on east side of entrance, easternmost section.	28
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Monumentation on east side of entrance, north-westernmost section.	29
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Monumentation on east side of entrance, north-westernmost section.	30
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	




Subject	Monumentation on east side of entrance, sign area.	31
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	
		

Subject	Monumentation on east side of entrance, sign area.	32
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Monumentation on east side of entrance, showing gold paint on wrought iron fence.	33
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	



Subject	Gold paint on wrought iron fence.	34
Site	Talcott Glen Storm Sewer System	
Date	9/26/2020	