

Regulated Contaminants

Disinfection By-Products	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2021	35	31-35	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHM)	2021	60	35.1 - 60.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Inorganic Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2021	0.043	0.015-0.043	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2021	6.8	4.5-6.8	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Flouride	2021	0.126	0.0886-0.126	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2021	0.0444	0.029 - 0.0444	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Radioactive Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	10/24/2018	1.5	1.5-1.5	0	5	pCi/L	N	Erosion of natural deposits

FIRST CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 MARTINSVILLE, TEXAS 75958  
 PERMIT NO. 1

SWIFT WATER SUPPLY  
 P.O. BOX 5  
 MARTINSVILLE, TEXAS 75958