

SPECIAL NOTICE

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office. You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791). If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Matthew Barrett at (936) 462-7843. Our water comes from the Carrizo/Wilcox aquifers, located in Nacogdoches County.

Source Water Name		Type of Water	Report Status	Location
4 - FM 2112 / S OF FM 1878	FM 2112 / S OF FM 1878	GW	<u>A</u>	<u>Nac County</u>
5 - FM 95 / N OF SH 7	FM 95 / N OF SH 7	GW	<u>A</u>	<u>Nac County</u>
6 - FM 2112	FM 2112	GW	<u>A</u>	<u>Nac County</u>
7 - 0.5 MI S WELL 6	0.5 MI S WELL 6	GW	<u>A</u>	<u>Nac County</u>
8 - PLANT 12	PLANT 12	GW	<u>A</u>	<u>Nac County</u>

Disinfectant Residual	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	
CHLORINE	2018	1.1	0.6	1.9	0.2	4.0	ppm	N	Water additive used to control microbes