

Regulated Contaminants

Disinfection By-Products	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2018	26	18.2 - 26.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHM)	2018	57	35.6 - 56.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Inorganic Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	12/08/2017	0.043	-0.043	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	12/08/2017	1.7	0 - 1.7	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Flouride	2018	0.124	0.124 - 0.124	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2018	0.0401	0.0256 - 0.0401	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Radioactive Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	10/08/2015	1.5	1.5-1.5	0	5	pCi/L	N	Erosion of natural deposits

FIRST CLASS MAIL
 U.S. POSTAGE
 PAID
 MARTINSVILLE, TEXAS 75958
 PERMIT NO. 1

SWIFT WATER SUPPLY
 P.O. BOX 5
 MARTINSVILLE, TEXAS 75958