



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1822

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Burridge & Heath Ltd

**Unit 7, Danbury Business Park
Danbury, Essex
CM3 4QJ
Tel. 01245677381**

Who fabricate the following timber fire doors and or doorsets:

**Strebord FD30, FD30S, FD60, FD60S.
Halspan FD30, FD30S, FD60, FD60S.**

have satisfied the requirements of the SDP 01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22 and Part 31**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes** integrity are detailed on page 2 of this certificate.

Initial Certification: 24 February 2023
Revised: 16 August 2024
Valid to: 23 February 2028
Issue status: 3

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Description	Fire Rating	Assessment/Test Report
Strebord 44mm	FD30	IFCA/08037
Strebord 54mm	FD60	IFCA/08038
Halspan XT / IT 60	FD60	PAR/21548/01
Safehinge Alumax / Halspan IT 60	FD30	Chilt/A12005 Test ref. 20220803-001608A
Pyroplex Rigid Box Fire and Smoke Seal	Smoke	WF167785
Pyroplex 15x4mm with integral brush pile only seal	Smoke	BMT/MTP/F14092/01*
Pyroplex 15x4mm with 3 integral bladed fins	Smoke	BMT/MTP/F14092/02*
Pyroplex 15x4mm with 2 integral bladed fins	Smoke	BMT/MTP/F14092/03*

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

*Refer to Technical Note TN/25285/01 for comparison between BS EN 1634-3:2004 and BS 476-31.1:1983 testing, allowing smoke seals tested to BS EN 1634-3:2004 to be included within the scope of this certificate.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.