

Schneider Electric™ Recalls 1.4 Million Electrical Panels Due to Thermal Burn and Fire Hazards

Name of Product:

Square™ D QO™ Plug-on-Neutral Load Centers™, also known as, Load Centers, Breaker Boxes, Electrical Panels

Hazard:

The load center can overheat, posing thermal burn and fire hazards.

Remedy:

Replace
Repair

Recall Date:

June 16, 2022

Units:

About 1.4 million (In addition, 289,000 were sold in Canada)

For more information on this recall go to: <https://www.cpsc.gov/Recalls/2022/Schneider-ElectricTM-Recalls-1-4-Million-Electrical-Panels-Due-to-Thermal-Burn-and-Fire-Hazards>

