**SFS** 

JOHN TREADWELL

TIM BOYLEN

DATE:

03/13/2020

RELEASED BY:

THIS DRAWING IS FOR SPATIAL CONSIDERATION ONLY, AND SUBJECT TO CHANGE W/O PREVIOUS NOTICE, DO NOT PRE-PLUMB TO THESE DIMENSIONS

| SAND FILTER                   | SFC54-LH   |  |  |
|-------------------------------|--|--|--|
|                               | Operating Point  | 318 GPM (US) @ 40' TDH   |  |
|                               | Sand Filter - Size & Style                                   | 54" Carbon Steel, Powder Coated  |  |
|                               | Frame Construction   | Carbon Steel (Welded), Powder Coated   |  |
|                               | Pipe Assy - Construction                                     | Carbon Steel (Welded), Powder Coated   |  |
|                               | ELECTRICAL - Motor & System                                  |  |  |
|                               | Horsepower (HP)  | 5  |  |
|                               | Power - Volts / Hz   | 460/60   |  |
|                               | RPM  | 3500   |  |
|                               | Motor Amperage   | 7.6  |  |
|                               | System Total Amperage  | 9.6  |  |
|                               | PUMP   |  |  |
|                               | Installation   | Flooded Suction Required   |  |
|                               | Case Material  | Cast Iron  |  |
|                               | Impeller Material  | Bronze   |  |
|                               | Mechanical Seal  | VITON Elastomer, Silicone Carbide Seat, Carbon Rotary  |  |
| BASKET STRAINER               |  | •  |  |
|                               | Body Construction  | Cast Iron  |  |
|                               | Strainer Mesh  | Stainless Steel with 1/4" perforations   |  |
|                               | Connection - Type & Size                                     | Flange 4"  |  |
|                               | CONTROL PANEL (UL Listed & Labeled. Manufactured to UL 508A) |  |  |
|                               | Enclosure  | NEMA 4 (STD)   |  |
|                               | (UL listed & CSA approved)                                   | NEMA 4X (Optional) - 304   |  |
|                               | Electrical Components  | Thermal Overload Starter, HOA, XFMR, "RUN" Light,  |  |
|                               | (UL listed & CSA approved)                                   | Door Disconnect, Contactor, Purge Timer  |  |
| CONTROL PANEL                 | PROCESS INLET  |  |  |
|                               | Connection - Type & Size                                     | Flange 4"  |  |
|                               | PROCESS OUTLET   |  |  |
|                               | Connection - Type & Size                                     | Flange 5"  |  |
|                               | VALVE ASSEMBLY   | Ta   |  |
|                               | Body Material  | Cast Iron, Powder Coated   |  |
|                               | Disc Material  | Cast Iron, Powder Coated   |  |
|                               | Connection Type  | Flanged, Butterfly   |  |
| PUMP & MOTOR                  | Seat   | EPDM 100 Florida Flori |  |
|                               | Electrical   | 120VAC Electric Actuator   |  |
|                               | Y-Strainer   | Cast Iron, 3/64" Perforation   |  |
|                               | Press Release & Air Vent                                     | 1" NPT   |  |
| SYSTEM FRAME——SYSTEM INLET    | PRESSURE - Maximum Oper                                      |  |  |
| 3131LIVITIONIL 3131LIVITINLET | Pump Inlet   | 60 psi (4.1 bar)   |  |
|                               | Vessel   | 80 psi (5.5 bar)   |  |
|                               | TEMPERATURE - Maximum  |  |  |
|                               | System   | 120°F (49°C)   |  |
|                               | WEIGHTS  | DRY SHIPPING OPERATING   |  |
| PREPARED BY: PAGE:            | lbs (kg)   | TBD 6685 (3032) 10615 (4815  |  |

\*UNLESS OTHERWISE SPECIFIED -ALL DIMENSIONS ARE IN INCHES SFC54-LH

SFS

THIS DRAWING IS FOR SPATIAL CONSIDERATION ONLY, AND SUBJECT TO CHANGE W/O PREVIOUS NOTICE, DO NOT PRE-PLUMB TO THESE DIMENSIONS







